

# Closet Lighting & Panel Location

Lighting fixtures—now also called luminaires—produce heat, and special precautions are needed to consider this heat in the selection and placement of fixtures.

<b>General</b>	<b>1999</b>	<b>2002</b>
<input type="checkbox"/> Wall switched lighting outlets req'd in all habitable rooms & bathrooms . . . . .	[210-70a1]	{210.70A1}
<input type="checkbox"/> Lighting outlet may be switched recep exc in kitchens & bathrooms . . . . .	[210-70a1X]	{210.70A1X}
<input type="checkbox"/> Switched lighting outlet on ext side of all grade level doors EXC		
<input type="checkbox"/> Garage vehicle door . . . . .	[210-70a2]	{210.70A2b}
<input type="checkbox"/> Switched light in utility, garage, hall & stairs . . . . .	[210-70a2]	{210.70A2b}
<input type="checkbox"/> Lighting outlet switched at entrance for basement, crawlspace or attic HVAC equip . . . . .	[210-70a3]	{210.70A3}

**Fig. 87  
Closet  
Lights**

